

Church security guidance

The prevention of arson in churches



Arson is the most common cause of fires in churches. Strong security and good housekeeping practices are the two main defences.

Losses can range from hundreds of pounds for minor damage to hundreds of thousands or even millions of pounds for major structural damage to a building. Even relatively small fires can generate large quantities of smoke and, when combined with cleaning costs, this often makes up a large portion of an arson claim. Whilst vandalism and theft can result in the unfortunate loss or damage of church treasures, fire has the potential to result in the total loss of both the church building and all its contents.

It is worth remembering that unlike an accidental fire, it is the arsonist's deliberate intention to set fire to the building and to cause damage. They will be looking, therefore, at ways of maximising damage. This may include the use of an accelerant, such as petrol, or starting fires in more than one place.

Strong security and good housekeeping practices are the two main defences against the risk of arson.

Security

Other than for services or other events, restrict the number of doors that may be used for access. Ideally only one door should be left unlocked. This door should be in a prominent position so that persons can be clearly seen entering and leaving the church. Doors in isolated locations which are not overlooked should be kept locked.

Any vegetation in the vicinity should be controlled to ensure this does not provide places to hide. Keep shrubbery below 1 metre in height. Before any works are undertaken on trees ensure they are not covered by a tree preservation order. Use the church as much as possible and encourage church members to include a walk around the church as part of their daily routines, such as while walking the dog, visiting the shops and neighbours. If possible, have a rota of church sitters.

Leaving a church open during daylight hours will encourage genuine visitors and will help to deter the potential arsonist. Churches should, however, be kept locked during the hours of darkness. Security lighting and CCTV can also act as deterrents to arsonists. Ensure all windows and doors are securely locked including outbuildings containing tools which could help an arsonist to break into the church. Some churches will feel that they have no option other than to keep the church locked unless someone is present. Do whatever you can to make it look as though the building is used on a regular basis. Seemingly vacant and unused buildings attract the attention of arsonists.

Opening and locking

Remember to undertake a routine search for anything unusual after opening and before locking the church.

Fire protection

The installation of automatic fire and/or intruder alarms will significantly reduce the risk of arson, particularly if they are linked to a permanently manned monitoring station. You must consult with Methodist Insurance before installing an alarm system. A premium discount may be allowed for approved alarm systems.

Ensure that you have a number of fire extinguishers in the church and that people know how to use them. Extinguishers also need to be maintained on an annual contract. It is not unknown for fires to be started when churches are occupied. The use of an extinguisher could prevent a major loss.

Good housekeeping

Do not make the arsonist's job any easier.

Matches and petrol should not be left in the church or outbuildings. Matches can easily be removed from the church and petrol should only be brought in as and when required for mowers.

Candles should be securely locked away.

Rubbish and combustible material must not be allowed to accumulate. This could include anything from bales of hay or straw used in the Christmas crib to polystyrene blocks used as 'stones' for the construction of the tomb in Easter gardens, both of which are highly combustible and could be used to start a fire.

Wheelie bins should be kept well away from all buildings, preferably at a distance of 10 metres away from the building and in a locked compartment.

Ensure all internal doors are closed when the church is left unoccupied. Internal doors act as firebreaks and prevent the spread of smoke from one part of a building to another. In one example where a church hall was set on fire, the cost of cleaning smoke damage to the adjoining church was many times that of completely rebuilding the hall, merely because the door between the hall and church had been left open.

Fire risk assessment

As the occupier of a building, you have a duty to undertake a fire risk assessment. The potential risk of arson is an important part of this assessment. Look at how a fire may be started and how this risk could be minimised by the reduction or removal of combustible materials or improving the security of the building. Arson fires are often started inside organs or under altars. Look at ways in which these risks may be reduced. Organ enclosures should be kept locked if possible and the space under altars should not be used for the storage of combustible materials. A record should be maintained of the measures you have put in place to reduce the risk of fire.

Useful resources

[Fire risk assessment form](#)

[Arson checklist](#)

Information in this document

This guidance is provided for information purposes and is general and educational in nature and does not constitute legal advice. You are free to choose whether or not to use it and it should not be considered a substitute for seeking professional help in specific circumstances. Accordingly, Methodist Insurance PLC shall not be liable for any losses, damages, charges or expenses, whether direct, indirect, or consequential and howsoever arising, that you suffer or incur as a result of or in connection with your use or reliance on the information provided in this guidance except for those which cannot be excluded by law. Where this guidance contains links to other sites and resources provided by third parties, these links are provided for your information only. Methodist Insurance is not responsible for the contents of those sites or resources. You acknowledge that over time the information provided in this guidance may become out of date and may not constitute best market practice.

Need to contact us?

For further information and advice on security for churches:

Call our Risk Management Advice Line on

0345 600 7531

Monday to Friday, 9am to 5pm (excluding Bank Holidays).

We may monitor or record calls to improve our service.

Email us at: riskadvice@micmail.co.uk



Methodist Insurance PLC
St Ann's House
St Ann's Place
Manchester M2 7LP
Tel: 0345 606 1331
www.methodistinsurance.co.uk

Methodist Insurance PLC (MIC) Reg. No. 6369. Registered in England at Beaufort House, Brunswick Road, Gloucester, GL1 1JZ. Methodist Insurance PLC is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority.